



Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services
Sepoy Bazar, P.O.:- Medinipur, P.S.:- Kotwali, Pin:- 721101

Memo no.: FSR/0125186241500033

Date: 24-03-2024

From:
Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services

To: JANA INTERNATIONAL SCHOOL
MOUZA-JAYANTIPUR, JL NO- 109, R.S. NO - 1059, UNDER CHANDROKANA MUNICIPALITY, PASCHIM
MEDINIPUR, PIN- 721201

Sub: Fire Safety Certificate for the occupancy of G+1 storied School Building in the name & style of "JANA INTERNATIONAL SCHOOL" under group of Educational Building at the premises at Mouza – Jayantipur, J.L. No.- 109, R.S. Plot No.-1059, under Chandrakona Municipality, Dist.-Paschim Medinipur, PIN-721201.

This is in reference to your application no. 0125189241500013 dated 03-03-2024 regarding the Fire Safety Certificate for the occupancy of G+1 storied School Building in the name & style of "JANA INTERNATIONAL SCHOOL" under group of Educational Building at the premises at Mouza – Jayantipur, J.L. No.-109, R.S. Plot No.-1059, under Chandrakona Municipality, Dist.-Paschim Medinipur, PIN-721201.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

Conditional Fire Safety Certificate allow subject to comply the following conditions with in Six month and intimated to this end for regularization of the Certificate.

Conditions:-

- The Third stair which recommended and showing in plan, must be completed for over coming the dead end.
- Require to provide a under ground reservoir having capacity not less than 20,000 Ltrs.
- Pump must be facilitated with auto driven mode.

Except the above, the general recommendations are as follows.-

- Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the drive way.
- Directional sign and escape route shall be displayed prominently.
- To eliminate risk of fire Hazards, Good housekeeping both for inside and outside of the building shall be strictly

maintained.

- 4.The interior finish decoration of building shall be made with low flame spread material conforming I.S. specification.
- 5.The notice of Fire Fighting and Evacuation with "Exit Sign" from the building shall be prepared and displayed at all vulnerable places of the building before taking occupancy.
- 6.The Employees and Security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
- 7.Mock Fire practice and Evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 8.First Aid Fire Fighting system shall be provided as per I.S. Specification.
- 9.Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition all the times.
- 10.If required the old line shall have to be replaced with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- 11.Periodical flashing of water from the Hydrant and Hose Reel Hose pipe line shall be made to maintain the efficient working performance o above mentioned system.
- 12.The Fire Safety Audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
- 13.Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in theme, particularly lines above false ceiling and ducts.
- 14.A Fire Control room including a close circuit T.V. system will have to be installed which will observe all the floor of the building.
- 15.Transformer and Switch gear room shall be protected with automatic CO2 or DCP Fire Extinguisher conforming I.S. Specification.
- 16.A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the building.
- 17.This Fire Safety Certificate is valid for three years and has to be renewed after three years from the date of issue of this letter as per Govt. Notification No. – 629_L dated 17/04/2018.
- 18.The Fire Safety Certificate is valid for three years and has to be renewed triennially from the date of issue of this letter Triennially a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services for performance of all the Life & Fire Safety Arrangements and Installations of the Building.
- 19.No Addition & Alteration without prior permission of West Bengal Fire & Emergency Services otherwise the Fire Safety Certificate will be treated as cancelled.

For Jayantipur Jana Foundation

Sanjit Jana
Secretary

Ranjit
PRINCIPAL

Jana International School
Jayantipur, Chandrakona
Paschim Medinipur, W.B. 721201

Signature Not Verified

Digitally Signed
Name: Barn Kumar Choudhury
Date: 24-Mar-2024 12:16:27
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services